



Certificate of Compliance

FIRE PROTECTION EQUIPMENT

This certificate is issued for the following Valve Switch equipment:

Equipment Model Designation(s): Safe Signal OSY2, OSY2A, PIBV2, PIBV2A

Approval Guide Listing: Category: 3135

☒ Electrical Signaling ☒ Supervisory Signal Initiating Devices ☒ Sprinkler System Supervision – Standard Security

Prepared for:

Potter Electric Signal Co LLC
1609 Park 370 Place
Hazelwood MO
63042
United States

Manufactured at:

Proansa
Blvd. Eje 1 S/N
esquina con Eje A
Sonora Navojoan 85895
Mexico

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standards and other documents:

Approval Standards

Class Number
3135

Date
2017

Other Standards

Organization, Designation Date

Original Approval Job Identification: 0W6A8.AY Approval Granted: 6 April 1993

Related Report: none

Subsequent Revisions: RR228700, RR228524

To verify the availability of the Approved product, please refer to www.approvalguide.com


J.E. Marquedant
VP, Manager - Electrical Systems
FM Approvals
1151 Boston-Providence Turnpike,
Norwood MA, 02062 USA

14 July 2021

Date

Member of the FM Global Group





Certificate of Compliance

☞ Electrical Signaling ☞ Supervisory Signal Initiating Devices ☞ Sprinkler System Supervision – Standard Security

Safe Signal Models OSY2, OSY2A

Gate Valve Switch. Models OSY2, OSY2A. For supervising open position of a gate valve. Model OSY2A is labeled for Canadian market and has factory installed cover tamper switch rated for 5 A at 125/250 V ac, 2.5 A at 24 V dc. Model 546-7000 cover tamper switch available for Model OSY2 rated for 5 A at 125/250 V ac, 2.5 A at 24 V dc.

Safe Signal Models PIBV2, PIBV2A

Post Indicator Valve Switch. Models PIBV2, PIBV2A. For supervising open position of a post indicator valve. Model PIBV2A is labeled for Canadian market and has factory installed cover tamper switch rated for 5 A at 125/250 V ac, 2.5 A at 24 V dc. Model 546-7000 cover tamper switch available for Model PIBV2 rated for 5 A at 125/250 V ac, 2.5 A at 24 V dc.



Member of the FM Global Group